



WIRED UP

ELECTRICAL SOLUTIONS

(Electrical Panel Manufacturer & Supplier)

CENTRAL POWER RESEARCH INSTITUTE


TEST REPORT




CPRI

Date : 24 May 2024

Test Report Number : CPRINOAHV24T0296
Name and Address of the Customer : M/s. Wired UP Electrical Solutions
Professor Colony, Ring Road No-01
Maa Kalimata Mandir, Raipur, Chhattisgarh-492001
Name and Address of the Manufacturer : M/s. Wired UP Electrical Solutions
Professor Colony, Ring Road No-01
Maa Kalimata Mandir, Raipur, Chhattisgarh-492001
Particulars of Sample tested : 415 V, 630 A, LT Panel
Type : Outdoor DB
Description of test sample : Refer Sheet 2 of 5
Serial Number : WIRED/24/65
Number of Sample tested : One
Date(s) of Test(s) : 16 & 17 May 2024
CPRI sample code number(s) : NOAHV24S0288
Particulars of test(s) conducted : Refer Sheet 3 of 5
Test in accordance with : IS/IEC 61439 (Part-1) : 2011 & IS/IEC 61439 (Part-2) : 2011
Standard/specification :
Sampling Plan : Nil
Customer's Requirement : Nil
Deviations, if any : Nil
Name of the witnessing persons :
Customer's Representatives : Mr. Anuj Kumar Srivastava
Test subcontracted with address of the laboratory : Nil
Documents constituting this report (in words)
Number of Sheet(s) : Five
Number of Oscillogram(s) : Nil
Number of Graph(s) : Nil
Number of Photograph(s) : One
Number of Test Circuit Diagram(s) : Nil
Number of Drawing(s) : Two


(Gangeshwar Singh)
Test Engineer




(M.K. Jaiswal)
Head of Division
Reviewed and Authorized by

ULR-TC5223240HVLT0296F

Discipline: Electrical Testing

Group: Transmission Line Equipment
& Accessories

HIGH VOLTAGE LABORATORY

REGIONAL TESTING LABORATORY, PLOT NO. 3

INSTITUTIONAL AREA, SECTOR-62, NOIDA-201309, (UP), INDIA.

FAX 0120-2402824 AND PHONE NO. 0120-2402823

Sheet 1 of 5